

Certificate of constancy of performance

according to Regulation (EU) No. 305/2011

Certificate No.: 1008-CPR-MC 69257207 0002

Report No.: 50082516 001; 50082516 002;

Applicant: X-SENSE TECHNOLOGY CO., LTD
8F/B, Qiaode Technology Zone, Guangming, Shenzhen, 518132,
P.R.China

Manufacturer: X-SENSE TECHNOLOGY CO., LTD
8F/B, Qiaode Technology Zone, Guangming, Shenzhen, 518132,
P.R.China

Manufacturing plant: X-SENSE TECHNOLOGY CO., LTD
8F/B, Qiaode Technology Zone, Guangming, Shenzhen, 518132,
P.R.China

Product: Smoke Alarm Devices

Identification: SD11; SD12; SD13; SD2J0AX; SD2K0AX; SD2L0AX
Photoelectric Smoke Detective
Intended use: Household smoke detection

FPC Report No.: 28246801 001

**System of assessment
and verification:** 1

Tested according to: EN 14604:2005/AC:2008

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 2017-08-16 and will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged. The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Date of issue:
Budapest, 2019-01-18



TÜV Rheinland InterCert Kft., Product Certification Body — H-1132 Budapest, Váci út 48/A, Hungary — www.tuv.com
Notified Body No. 1008

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	EN 14604: 2005 + AC:2008
Repeatability	Pass	
Directional dependence	Pass	
Initial sensitivity	Pass	
Air movement	Pass	
Dazzling (45°, 90°)	Pass	
Dry heat (55±2°C, 2h)	Pass	
Cold (operational) (0±2°C, 2h)	Pass	
Damp heat (operational) (40±2°C, 93±3%, 96h)	Pass	
Sulphur dioxide (SO ₂) corrosion (25 °C; 93 %; 25 ppm; 4 days)	Pass	
Impact (1,9±0,1 J; 1 time)	Pass	
Vibration (operational) (10 to 150 Hz; 5m/s ² ; 3 axes)	Pass	
Vibration (endurance) (10 to 150 Hz; 10m/s ² ; 3 axes)	Pass	
Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	
Fire sensitivity (TF2; TF3; TF4; TF5)	Pass	
Battery fault warning	Pass	
Sound output	Pass	
Sounder durability	Pass	
Variation in supply voltage	Pass	
Alarm silence facility	Pass	
Battery reversal	N/A	
Electrical safety	Pass	

Certifier

Date of issue:

Budapest, 2019-01-18



TÜV Rheinland InterCert Kft., Product Certification Body — H-1132 Budapest, Váci út 48/a-b, Hungary — www.tuv.com
Notified Body No. 1008